

DECLARATION OF PERFORMANCE

No 0182-2/DWU/S/2203

1. Unique identification code of the product-type: **BiT 500 (St)CH 300/500 V (1)**
2. Intended use/es: **Supply of electricity and communications in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke**
3. Manufacturer: **Zakłady Kablowe BITNER sp. z o.o.
ul. Friedleina 3/3, 30-009 KRAKÓW
Production plant: ul. Krakowska 2, 32-353 TRZYCIĄŻ**
4. System/s of AVCP: **3**
5. Harmonised standard: **EN 50575:2014
EN 50575:2014/A1:2016**
6. Notified body/ies: **NB 1488**
7. Declared performance/s:

Essential Characteristics	Performance	Range
Reaction to fire	Dca-s1,d1,a1	(12÷61)x0,5; (14÷61)x0,75; (14÷61)x1,0; (18÷61)x1,5; (30÷50)x2,5; 2x4; 4x(6÷16); (2÷24)x(2x0,5); (2÷24)x(2x0,75); (2÷24)x(2x1,0); (2÷24)x(2x1,5); (2÷16)x(2x2,5)
Dangerous substances	NPD	

8. Appropriate Technical Documentation and/or Specific Technical Documentation:

03374/21/Z00NZP-

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

ZAKŁADY KABLOWE BITNER

sp. z o.o.
Ul. Józefa Friedleina 3/3, 30-009 Kraków
Dyrektor ds. rozwoju, certyfikacji i kontroli jakości

Ireneusz Sosnowski

Ireneusz Sosnowski

At Trzyciąż, on 2022-03-18

This document replaces DoP no 0182-2/DWU/S/2017.