


DECLARATION OF PERFORMANCE

No 0211/DWU/S/2304

1. Unique identification code of the product-type: **CB0211**
2. Name allowing identification of the product as required under Article 11(4): **BiT 1000 HCH 0,6/1 kV (1)**
3. Intended use/es: **Supply of electricity and communications in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke** 
4. Manufacturer: **Zakłady Kablowe BITNER sp. z o.o.
ul. Friedleina 3/3, 30-009 KRAKÓW
Production plant: ul. Krakowska 2, 32-353 TRZYCIĄŻ**
5. System/s of AVCP: **3**
6. Harmonised standard: **EN 50575:2014
EN 50575:2014/A1:2016**
7. Notified body/ies: **NB 1488**
8. Declared performance/s:

Essential Characteristics	Performance	Range
Reaction to fire	Dca-s1b,d0,a1	NOTE: Range below covers also cables with green-yellow protective conductor (G). (2, 3, 4, 5, 6, 7, 8, 10, 12, 14, 16, 18, 19, 20, 21, 25)x1,0; (2, 3, 4, 5, 6, 7, 8, 10, 12, 14, 16, 18, 19, 20, 21, 24, 25)x1,5; (2, 3, 4, 5, 6, 7, 8, 10, 12, 14, 16, 18, 19, 20, 21, 24, 25)x2,5; (3, 4, 5, 19)x4,0; (4, 5, 7)x6,0; (2, 4)x10; 4x16
Dangerous substances	NPD	

9. Appropriate Technical Documentation and/or Specific Technical Documentation:

-

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

ZAKŁADY KABLOWE BITNER

sp. z o.o.
Ul. Józefa Friedleina 3/3, 30-009 Kraków
Dyrektor ds. rozwoju, certyfikacji i kontroli jakości

Ireneusz Sosnowski

.....
Ireneusz Sosnowski

At Trzyciąż, on 2023-04-25

This document replaces DoP no. 0211/DWU/S/2017.