

## DECLARATION OF PERFORMANCE

No 0200/DWU/T/2304

1. Unique identification code of the product-type: **CB0200**
2. Name allowing identification of the product as required under Article 11(4): **FQAR-PG 150/250 V**
3. Intended use/es: **Supply of electricity and communications in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke**
4. Manufacturer: **Zakłady Kablowe BITNER sp. z o.o.  
ul. Friedleina 3/3, 30-009 KRAKÓW  
Production plant: ul. Krakowska 2, 32-353 TRZYCIĄŻ**
5. System/s of AVCP: **3**
6. Harmonised standard: **EN 50575:2014  
EN 50575:2014/A1:2016**
7. Notified body/ies: **NB 1438**
8. Declared performance/s:

Essential Characteristics	Performance	Range
Reaction to fire	<b>Dca-s1b,d1,a1</b>	<b>1x2x0,5; 2x2x0,5; 4x2x0,5; 8x2x0,5; 16x2x0,5</b>
Dangerous substances	<b>NPD</b>	<b>1x2x1,0; 2x2x1,0; 4x2x1,0; 8x2x1,0; 16x2x1,0</b>

9. Appropriate Technical Documentation and/or Specific Technical Documentation:

**The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.**

Signed for and on behalf of the manufacturer  
by:

**ZAKŁADY KABLOWE BITNER**

sp. z o.o.  
Ul. Józefa Friedleina 3/3, 30-009 Kraków  
Dyrektor ds. rozwoju, certyfikacji i kontroli jakości

*Ireneusz Sosnowski*  
Ireneusz Sosnowski

At Trzyciąż, on 2023-04-25

*This document replaces DoP no. 0200/DWU/T/2017.*