

DECLARATION OF PERFORMANCE

No 0211/DWU/S/2017

- | | |
|--|---|
| 1. Unique identification code of the product-type: | BiT 1000 HCH 0,6/1 kV (1) |
| 2. Intended use/es: | Supply of electricity and communications in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke |
| 3. Manufacturer: | Zakłady Kablowe BITNER sp. z o.o. ul. Friedleina 3/3, 30-009 KRAKÓW Production plant: ul. Krakowska 2, 32-353 TRZYCIĄŻ |
| 4. System/s of AVCP: | 3 |
| 5. Harmonised standard: | EN 50575:2014 EN 50575:2014/A1:2016 |
| 6. Notified body/ies: | NB 1488 |
| 7. Declared performance/s: | |

| Essential Characteristics | Performance | Range |
|---------------------------|----------------------|---|
| Reaction to fire | Dca-s1b,d0,a1 | NOTE! The range below covers also cables with green and yellow protective conductor! (2, 3, 4, 5, 6, 7, 8, 10, 12, 14, 16, 18, 19, 20, 21, 25)x1,0; (2, 3, 4, 5, 6, 7, 8, 10, 12, 14, 16, 18, 19, 20, 21, 24, 25)x1,5; (2, 3, 4, 5, 6, 7, 8, 10, 12, 14, 16, 18, 19, 20, 21, 24, 25)x2,5; (3, 4, 5, 19)x4,0; (4, 5, 7)x6,0; (2, 4)x10; 4x16 |
| Dangerous substances | NPD | |

8. Appropriate Technical Documentation and/or Specific Technical Documentation:

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

ZAKŁADY KABLOWE BITNER
 sp. z o.o.
 Ul. Józefa Friedleina 3/3, 30-009 Kraków
 Dyrektor ds. rozwoju, certyfikacji i kontroli jakości

Ireneusz Sosnowski

Ireneusz Sosnowski

At Trzyciąż, on 2021-01-19

This document replaces DoP no 0211/DWU/S/2017 of 2020-07-15.