

## DECLARATION OF PERFORMANCE

No 0409/DWU/E/2017

1. Unique identification code of the product-type: **N2XCH 0,6/1 kV (1)**
2. Intended use/es: **Supply of electricity and communications in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke**
3. Manufacturer: **Zakłady Kablowe BITNER sp. z o.o.  
ul. Friedleina 3/3, 30-009 KRAKÓW  
Production plant: ul. Krakowska 2, 32-353 TRZYCIĄŻ**
4. System/s of AVCP: **3**
5. Harmonised standard: **EN 50575:2014  
EN 50575:2014/A1:2016**
6. Notified body/ies: **NB 1488**
7. Declared performance/s:

Essential Characteristics	Performance	Range
Reaction to fire	<b>Dca-s1b,d0,a1</b>	2x(1,5-16)RE; 2x(25-70)RM; 3x(1,5-16)RE; 3x(25-300)RM; 4x(1,5-16)RE; 4x(25-300)RM;
Dangerous substances	<b>NPD</b>	7x(1,5-4)RE; 10x(1,5-4)RE; 12x(1,5-2,5)RE; 14x1,5RE; 19x1,5RE/4;

8. Appropriate Technical Documentation and/or Specific Technical Documentation:

**The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.**

Signed for and on behalf of the manufacturer by:

**ZAKŁADY KABLOWE BITNER**  
sp. z o.o.  
Ul. Józefa Friedleina 3/3, 30-009 Kraków  
Dyrektor ds. rozwoju, certyfikacji i kontroli jakości

*Ireneusz Sosnowski*

.....  
Ireneusz Sosnowski

At Trzyciąż, on 2021-03-02

*This document replaces DoP no 0409/DWU/E/2017 of 2021-01-26.*